



Lead Testing in School Drinking Water



Location:

Brockport Central School District
Brockport, New York 14559

Prepared for:

Brockport Central School District
40 Allen Street
Brockport, NY 14420

LaBella Project No. 2211782

June 30, 2021

Table of Contents

	Page No.
I. Background	1
II. Project Description	1
III. Sampling Procedures and Summary of Results	2
IV. Response and Recommendations	7
V. Reporting and Record Keeping	7

Appendix A – Detailed Results Spreadsheet

Appendix B – Laboratory Analytical Reports

Appendix C – Licenses and Certifications

I. BACKGROUND

Under Subpart 67-4 of the New York Codes, Rules and Regulations, Title X, “all school districts and boards of cooperative educational services are required to test potable water for lead contamination, and to develop and implement a lead remediation plan, where applicable.”

The Subpart 67-4 testing requirement was first promulgated under emergency legislation in 2016, and was subsequently signed into permanent law. The regulation requires that testing be performed again in 2020, and every five years thereafter. Due to the COVID-19 Pandemic, NYSDOH has granted an extension for this testing until June 30, 2021.

Lead is a toxic metal that can be harmful to human health when ingested. Young children, especially those 6 years and younger, are at particular risk for lead exposure because they have frequent hand-to-mouth activity and absorb lead more easily than do adults. Children’s nervous systems are still undergoing development and thus are more susceptible to the effects of toxicants. Therefore, emphasis may be placed on assessment of lead exposure in schools and early childhood education facilities, where concentrations of a vulnerable population are regularly congregated.

Lead can be introduced into potable water by being present in the source water or, more commonly, by interaction of the water with fixtures and plumbing materials containing lead. Common sources of lead in potable water include solder, fluxes, pipes and pipe fittings, fixtures, and sediments. It is possible that different water outlets in a given building could have dissimilar concentrations of lead. It is also possible that, due to temporal fluctuations in water chemistry and physical conditions that may affect the integrity of the plumbing and the water being conveyed, the result obtained from a test at a given time may differ from the result obtained from a test at another time, even if the sampling procedures are identical.

II. PROJECT DESCRIPTION

Due to COVID-19 restrictions imposed by New York State in March of 2020, the Brockport Central School District adopted a “hybrid” teaching model which led to only partial capacity of student/teacher populations at their schools on a given day. As part of this model, drinking fountains were disabled and therefore not included in this testing.

Sampling by LaBella Associates and district staff began in May 2021. A total of ten (10) samples were lost in transit while shipping to the lab. These were resampled in a secondary round of testing. Results in this report address sampling completed between May and June 2021.

In accordance with sections 1370-a and 1110, Subpart 67-4 of Title 10 (Health) of the Official Compilation of Codes, Rules and Regulations of the State of New York and US EPA Guidelines, LaBella Associates performed sampling of potable water for lead contaminants for the Brockport Central School District. Sampling was conducted between May and June 2021 at the following locations:

- Ginther Elementary School
- Barclay Elementary
- Fred W. Hill Elementary School
- A.D. Oliver Middle School
- Brockport High School
- Transportation Facility
- Administration Building
- TTC Building
- Operations Building
- Maintenance Building
- Brockport High School Concessions Building

III. SAMPLING PROCEDURES AND SUMMARY OF RESULTS

LaBella Associates conducted a site walkthrough with district maintenance personnel to identify potable outlets required for testing. These outlets included bottle fillers, kitchen sinks, classroom sinks, and medical office sinks. Outlets categorically excluded from testing may include showers, science room sinks, art room sinks, tempered faucets, and mechanical room outlets. Also, drinking fountains and bubblers were excluded from testing as they were disabled due to COVID restrictions. Typically, excluded outlets are capable of being isolated by custodial staff, or are accompanied by warning signs to prohibit consumption.

In all locations, over multiple dates, LaBella staff conducted sampling of target outlets prior to the facility opening and before any water was used. Some of the fixtures were out of service on the day of sampling. The water conditions were reported to be representative of normal consumption patterns (given current occupancy rates) with building occupancy controlled during stagnation and sampling periods.

In accordance with Subpart 67-4 requirements, sampling was limited to “first-draw” samples. A volume of the first 250 mL of water was taken from each cold water outlet in the inventory.

The samples were then promptly packaged and shipped to a NYS Department of Health Environmental Laboratory Approval Program (ELAP) accredited laboratory. Samples were analyzed utilizing EPA environmental analysis method 200.9 Rev 2.2 for lead in potable water.

Once the results from the initial round of testing were delivered, outlets that had exceeded the Environmental Protection Agency (EPA) lead in drinking water action were identified. District maintenance personnel applied remediation measures on the identified outlets. A second round of testing consisted of these outlets, as well as outlets that had been lost in shipping or were not functional during the initial testing round. Results of the laboratory analyses, field testing and the visual on-site inspection were compiled and summarized.

Ginther Elementary School Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
58	57	1

Barclay Elementary School Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
57	54	3

Fred W. Hill Elementary School Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
76	75	1

A.D. Oliver Middle School Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
47	44	3

Brockport High School Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
92	85	7

Transportation Facility Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
11	11	0

Administration Building Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
5	4	1

TTC Building Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
11	11	0

Operations Building Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
4	4	0

Maintenance Building Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
3	3	0

Brockport High School Concessions Sampling Summary		
Total Number of Outlets	Number of outlets at or below EPA action level (15 µg/L)	Number of outlets above EPA action level (15 µg/L)
8	4	4

Based on laboratory analyses of the samples collected, the following outlets were determined to exceed the EPA action level of 15 parts per billion (ppb) or equivalent 15 micrograms per liter (µg/L). This table includes the outlets that failed both the initial and secondary rounds of testing. For a full list of outlets sampled see Appendix A immediately following this report.

Ginther Elementary School Samples Exceeding Action Level, Post-Remediation			
Sample ID	Sample Description	Date Sampled	Result (µg/L)
GIN-01-T-IN-505-T	Restroom 505 Sink	5/26/2021	19.7
GIN-01-T-IN-505-T	Restroom 505 Sink, Retest	6/11/2021	27.6

Barclay Elementary School Samples Exceeding Action Level, Post-Remediation			
Sample ID	Sample Description	Date Sampled	Result (µg/L)
BAR-01-EXT-BY-606-HB	Ext by Classroom 606 Hose Bib	5/27/2021	22.3
BAR-01-CR-IN-120-T	Office 120 Sink	5/27/2021	32.5
BAR-01-T-IN-120-T	Office Restroom 120 Sink	5/27/2021	63.6
BAR-01-EXT-BY-606-HB	Ext by Classroom 606 Hose Bib, Retest	6/11/2021	36.5
BAR-01-CR-IN-120-T	Office 120 Sink, Retest	6/11/2021	31.9
BAR-01-T-IN-120-T	Office Restroom 120 Sink, Retest	6/11/2021	54.9

Fred W. Hill Elementary School Samples Exceeding Action Level, Post-Remediation			
Sample ID	Sample Description	Date Sampled	Result (µg/L)
FWH-01-KIT-IN-119-PF1	Kitchen 119 Pot Filler 1	5/27/2021	18.4
FWH-01-KIT-IN-119-PF1	Kitchen 119 Pot Filler 1, Retest	6/11/2021	17.8

A.D. Oliver Middle School Samples Exceeding Action Level, Post-Remediation			
Sample ID	Sample Description	Date Sampled	Result (µg/L)
OMS-02-CR-IN-153-T2	Classroom 153 Right Sink	5/27/2021	28.5
OMS-03-GO-IN-101C-T	Gym Office 101C Sink	5/27/2021	18.1
OMS-03-GO-IN-101A-T	Gym Office 101A Sink	5/27/2021	41.5
OMS-02-CR-IN-153-T2	Classroom 153 Right Sink, Retest	6/11/2021	36.5

A.D. Oliver Middle School Samples Exceeding Action Level, Post-Remediation			
Sample ID	Sample Description	Date Sampled	Result (µg/L)
OMS-03-GO-IN-101C-T	Gym Office 101C Sink, Retest	6/11/2021	21.7
OMS-03-GO-IN-101A-T	Gym Office 101A Sink, Retest	6/11/2021	41.7

Brockport High School Samples Exceeding Action Level, Post-Remediation			
Sample ID	Sample Description	Date Sampled	Result (µg/L)
BHS-00-CR-IN-013-T	Classroom 013 Sink	5/26/2021	23.2
BHS-00-CR-IN-014-T	Classroom 014 Sink	5/26/2021	101
BHS-01-BT-IN-138G-T	Girl's Restroom 138G Tap	5/26/2021	50.4
BHS-01-GLR-IN-197-T1	Girl's Locker Room 197 Left Sink	5/26/2021	55.3
BHS-01-NO-IN-175C-T	Nurse's Exam Room C Sink	5/26/2021	21.4
BHS-00-CR-IN-013-T	Classroom 013 Sink, Retest	6/11/2021	30.4
BHS-00-CR-IN-014-T	Classroom 014 Sink, Retest	6/11/2021	29.9
BHS-01-BT-IN-138G-T	Girl's Restroom 138G Tap, Retest	6/11/2021	55.1
BHS-01-GLR-IN-197-T1	Girl's Locker Room 197 Left Sink, Retest	6/11/2021	25.4
BHS-01-GLR-IN-197-T2	Girl's Locker Room 197 Right Sink	6/11/2021	37.2
BHS-01-NO-IN-175D-T	Nurse's Exam Room D Sink, Retest	6/11/2021	22.8
BHS-01-NO-IN-175C-T	Nurse's Exam Room C Sink, Retest	6/11/2021	54.4

Administration Building Samples Exceeding Action Level			
Sample ID	Sample Description	Date Sampled	Result (µg/L)
ADM-01-EXT-BY-22-HB	Hose Bib by 22	5/28/2021	16.6

Brockport High School Concessions Middle School Samples Exceeding Action Level			
Sample ID	Sample Description	Date Sampled	Result (µg/L)
CON-01-EXT-BY-CON-HB1	Hose Bib by Bathrooms	6/11/2021	19.7
CON-01-EXT-BY-CON-HB2	Hose Bib by Serving Window	6/11/2021	59.9
CON-01-EXT-BY-CON-HL1	Field Hose Line, East Side	6/11/2021	24.2
CON-01-EXT-BY-CON-HL2	Field Hose Line, West Side	6/11/2021	62.5

IV. Response and Recommendations

According to section Subpart 67-4.4 “Response” of the regulation, school districts shall prohibit the use of all outlets which exceed the 15 µg action level. The outlet shall remain out of service until a lead remediation plan is implemented to reduce the level of lead, and resampling indicates lead levels at or below the action level. While the outlet is out of service, the district must supply an appropriate amount of potable water for drinking or cooking to building occupants.

LaBella would provide the following recommendations for outlets in exceedance of the action level:

1. Follow up testing – This may include an additional first draw sample, or second draw sample to further investigate and evaluate the condition of the plumbing system upstream of the affected outlets. Sample results may provide some insight on trends, issues with certain portions of the plumbing system, or links to specific outlets types and models.
2. Remedial Measures – The school district may elect to commence remediation of affected outlets with or without additional testing. Temporary remediation could include isolating outlets and providing alternate sources of potable drinking or cooking water. Permanent remediation could include replacing outlets, permanently isolating outlets, adding water filtration, or renovations to the plumbing system.

V. Reporting and Record Keeping

In accordance with Subpart 67-4 the district shall:

- Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report.
- Notify all staff and all persons in parental relation to children or students of the test results, in writing, as soon as practicable, but no more than 10 business days after the school received the laboratory report.
- The school shall make available, on the school’s website, the results of all lead testing

performed and lead remediation plans implemented pursuant to this Subpart, as soon as practicable, but no more than 6 weeks after the school received the laboratory reports.

- As soon as practicable, but no more than 10 business days after the school received the laboratory reports, the school shall report data relating to test results to the Department, local health department, and State Education Department, through the Department's designated statewide electronic reporting system.
- The school shall retain all records of test results, lead remediation plans, determinations that a building is lead-free, and waiver requests, for ten years following the creation of such documentation. Copies of such documentation shall be immediately provided to the Department, local health department, or State Education Department, upon request.

Appendix A

Detailed Results Spreadsheet

Ginther Elementary School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	GIN-01-T-IN-520-T	Restroom 520 Sink	5/26/2021	707	<5.00
2	GIN-01-T-IN-522-T	Restroom 522 Sink	5/26/2021	708	<5.00
3	GIN-01-RM-IN-512-T	Room 512 Sink	5/26/2021	709	<5.00
4	GIN-01-HA-BY-512-BF	Bottle Filler by 512	5/26/2021	710	<5.00
5	GIN-01-KIT-IN-504-Sprayer	Kitchen 504 Sprayer	5/26/2021	712	<5.00
6	GIN-01-KIT-IN-504-T	Kitchen 504 Sink	5/26/2021	713	<5.00
7	GIN-01-RM-IN-511-T1	Room 511 Sink 1	5/26/2021	715	<5.00
8	GIN-01-RM-IN-511-T2	Room 511 Sink 2	5/26/2021	715	<5.00
9	GIN-01-RM-IN-511-T3	Room 511 Sink 3	5/26/2021	716	<5.00
10	GIN-01-T-IN-509-T	Restroom 509 Sink	5/26/2021	717	<5.00
11	GIN-01-T-IN-505-T	Restroom 505 Sink	5/26/2021	717	19.7
12	GIN-01-T-IN-503-T	Restroom 503 Sink	5/26/2021	718	<5.00
13	GIN-01-FR-IN-100-T	Faculty Room 100 Sink	5/26/2021	719	<5.00
14	GIN-01-FR-IN-100-CT	Faculty Room 100 Coffee Line	5/26/2021	719	<5.00
15	GIN-01-T-IN-100-T	Faculty Room 100 Restroom Sink	5/26/2021	721	<5.00
16	GIN-01-HA-BY-101-BF	Bottle Filler by Main Office 101	5/26/2021	724	<5.00
17	GIN-01-T-IN-101-T	Main Office Restroom 101 Sink	5/26/2021	725	<5.00
18	GIN-01-OF-IN-101C-T	Main Office 101C Sink	5/26/2021	725	<5.00
19	GIN-01-OF-IN-101E-T	Main Office 101E Sink	5/26/2021	726	<5.00
20	GIN-01-T-BY-107-T	Restroom by 107 Sink	5/26/2021	726	<5.00
21	GIN-01-RM-IN-106-T	Conference Room 106 Sink	5/26/2021	727	<5.00
22	GIN-01-CR-IN-108-T	Classroom 108 Sink	5/26/2021	730	<5.00
23	GIN-01-T-IN-108-T	Classroom 108 Restroom Sink	5/26/2021	730	<5.00
24	GIN-01-CR-IN-109-T	Classroom 109 Sink	5/26/2021	731	<5.00
25	GIN-01-CR-IN-110-T	Classroom 110 Sink	5/26/2021	732	<5.00
26	GIN-01-CR-IN-111-T	Classroom 111 Sink	5/26/2021	733	<5.00
27	GIN-01-CR-IN-112-T	Classroom 112 Sink	5/26/2021	734	<5.00
28	GIN-01-CR-IN-113-T	Classroom 113 Sink	5/26/2021	736	<5.00
29	GIN-01-CR-IN-114-T	Classroom 114 Sink	5/26/2021	736	<5.00
30	GIN-01-CR-IN-115-T	Classroom 115 Sink	5/26/2021	737	<5.00
31	GIN-01-CR-IN-116-T	Classroom 116 Sink	5/26/2021	737	<5.00
32	GIN-01-CR-IN-400-T	Classroom 400 Sink	5/26/2021	739	<5.00
33	GIN-01-CR-IN-401-T	Classroom 401 Sink	5/26/2021	740	5.84
34	GIN-01-CR-IN-402-T	Classroom 402 Sink	5/26/2021	742	<5.00
35	GIN-01-CR-IN-403-T	Classroom 403 Sink	5/26/2021	742	6.37
36	GIN-01-CR-IN-404-T	Classroom 404 Sink	5/26/2021	743	<5.00
37	GIN-01-CR-IN-405-T	Classroom 405 Sink	5/26/2021	744	<5.00
38	GIN-01-CR-IN-406-T	Classroom 406 Sink	5/26/2021	745	<5.00
39	GIN-01-T2-IN-316-T	Library 316 Right Restroom Sink	5/26/2021	745	<5.00
40	GIN-01-T1-IN-316-T	Library 316 Left Restroom Sink	5/26/2021	745	<5.00
41	GIN-01-LIB-IN-316A-T	Library 316A Sink	5/26/2021	746	Lost
42	GIN-01-CR-IN-321-T	Classroom 321 Sink	5/26/2021	748	Lost
43	GIN-01-CR-IN-314-T	Classroom 314 Sink	5/26/2021	749	Lost

Ginther Elementary School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
44	GIN-01-CR-IN-312-T	Classroom 312 Sink	5/26/2021	750	<5.00
45	GIN-01-CR-IN-310-T	Classroom 310 Sink	5/26/2021	751	<5.00
46	GIN-01-T-IN-309A-T	Restroom 309A Sink	5/26/2021	752	<5.00
47	GIN-01-CR-IN-308-T	Classroom 308 Sink	5/26/2021	752	15.4
48	GIN-01-T-IN-303-T	Restroom 303 Sink	5/26/2021	753	Lost
49	GIN-01-CR-IN-200-T	Classroom 200 Sink	5/26/2021	754	<5.00
50	GIN-01-CR-IN-201-T	Classroom 201 Sink	5/26/2021	755	<5.00
51	GIN-01-CR-IN-202-T	Classroom 202 Sink	5/26/2021	756	<5.00
52	GIN-01-CR-IN-203-T	Classroom 203 Sink	5/26/2021	757	<5.00
53	GIN-01-CR-IN-204-T	Classroom 204 Sink	5/26/2021	758	<5.00
54	GIN-01-CR-IN-205-T	Classroom 205 Sink	5/26/2021	759	<5.00
55	GIN-01-CR-IN-206-T	Classroom 206 Sink	5/26/2021	800	<5.00
56	GIN-01-CR-IN-207-T	Classroom 207 Sink	5/26/2021	801	<5.00
57	GIN-01-CR-IN-208-T	Classroom 208 Sink	5/26/2021	801	<5.00
58	GIN-01-CR-IN-209-T	Classroom 209 Sink	5/26/2021	802	<5.00
59	GIN-01-T-IN-505-T	Restroom 505 Sink, Retest	6/11/2021	540	27.6
60	GIN-01-LIB-IN-316A-T	Library 316A Sink, Retest	6/11/2021	544	<5.00
61	GIN-01-CR-IN-321-T	Classroom 321 Sink, Retest	6/11/2021	546	5.32
62	GIN-01-CR-IN-314-T	Classroom 314 Sink, Retest	6/11/2021	547	<5.00
63	GIN-01-CR-IN-308-T	Classroom 308 Sink, Retest	6/11/2021	548	13.3

Barclay Elementary School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	BAR-01-T-IN-101-T	Restroom 101 Sink	5/27/2021	610	7.69
2	BAR-01-HA-BY-100-BF	Bottle Filler by Restroom 100	5/27/2021	611	<5.00
3	BAR-01-T-IN-101C-T	Restroom 101C Sink	5/27/2021	613	24.5
4	BAR-01-KIT-IN-106-T1	Kitchen 106 Sink 1	5/27/2021	501	20.7
5	BAR-01-KIT-IN-106-T2	Kitchen 106 Sink 2	5/27/2021	501	<5.00
6	BAR-01-KIT-IN-106-T3	Kitchen 106 Sink 3	5/27/2021	502	6.1
7	BAR-01-FAC-IN-108-T	Faculty Room 108 Sink	5/27/2021	614	<5.00
8	BAR-01-FAC-IN-108-CT	Faculty Room 108 Coffee Line	5/27/2021	615	<5.00
9	BAR-01-T-IN-105-T	Restroom 105 Sink	5/27/2021	616	<5.00
10	BAR-01-MT-IN-200M-T	Men's Restroom 200M Sink	5/27/2021	618	<5.00
11	BAR-01-WT-IN-200W-T	Women's Restroom 200W Sink	5/27/2021	618	<5.00
12	BAR-01-T-IN-204-T	Classroom 204 Restroom Sink	5/27/2021	619	<5.00
13	BAR-01-T-IN-205-T	Classroom 205 Restroom Sink	5/27/2021	620	<5.00
14	BAR-01-EXT-BY-103-HB	Exterior by Gym 103 Hose Bib	5/27/2021	622	<5.00
15	BAR-01-CR-IN-601-T	Classroom 601 Sink	5/27/2021	621	<5.00
16	BAR-01-CR-IN-602-T	Classroom 602 Sink	5/27/2021	622	<5.00
17	BAR-01-CR-IN-603-T	Classroom 603 Sink	5/27/2021	623	<5.00
18	BAR-01-CR-IN-604-T	Classroom 604 Sink	5/27/2021	623	<5.00
19	BAR-01-CR-IN-605-T	Classroom 605 Sink	5/27/2021	624	<5.00
20	BAR-01-CR-IN-606-T	Classroom 606 Sink	5/27/2021	626	<5.00
21	BAR-01-T-IN-606-T	Classroom Restroom 606 Sink	5/27/2021	628	<5.00
22	BAR-01-EXT-BY-606-HB	Hose Bib by Classroom 606	5/27/2021	630	22.3
23	BAR-01-CR-IN-607-T	Classroom 607 Sink	5/27/2021	630	<5.00
24	BAR-01-T-IN-607-T	Classroom Restroom 607 Sink	5/27/2021	630	8.5
25	BAR-01-CR-IN-609-T	Classroom 609 Sink	5/27/2021	631	<5.00
26	BAR-01-EXT-BY-609-HB	Exterior by Classroom 609 Hose Bib	5/27/2021	631	9.58
27	BAR-01-CR-IN-610-T	Classroom 610 Sink	5/27/2021	632	<5.00
28	BAR-01-T-IN-611-T	Restroom 611 Sink	5/27/2021	632	<5.00
29	BAR-01-CR-IN-612-T	Classroom 612 Sink	5/27/2021	632	<5.00
30	BAR-01-CR-IN-613-T	Classroom 613 Sink	5/27/2021	633	<5.00
31	BAR-01-CR-IN-614-T	Classroom 614 Sink	5/27/2021	634	<5.00
32	BAR-01-CR-IN-615-T	Classroom 615 Sink	5/27/2021	634	<5.00
33	BAR-01-NO-IN-115-T	Nurse's Office 115 Sink	5/27/2021	634	<5.00
34	BAR-01-NO-IN-115A-T	Nurse's Office Restroom 115A Sink	5/27/2021	636	<5.00
35	BAR-01-CR-IN-302-T	Classroom 302 Sink	5/27/2021	636	5.49
36	BAR-01-CR-IN-304-T	Classroom 304 Sink	5/27/2021	638	6.43
37	BAR-01-CR-IN-305-T	Classroom 305 Sink	5/27/2021	639	14.5
38	BAR-01-CR-IN-306-T	Classroom 306 Sink	5/27/2021	640	6.35
39	BAR-01-CR-IN-307-T	Classroom 307 Sink	5/27/2021	641	<5.00
40	BAR-01-CR-IN-308-T	Classroom 308 Sink	5/27/2021	642	13.7
41	BAR-01-CR-IN-309-T	Classroom 309 Sink	5/27/2021	642	8.19
42	BAR-01-CR-IN-120-T	Office 120 Sink	5/27/2021	646	32.5

Barclay Elementary School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
43	BAR-01-T-IN-120-T	Office Restroom 120 Sink	5/27/2021	646	63.6
44	BAR-01-T-IN-132-T	Classroom Restroom 132 Sink	5/27/2021	647	<5.00
45	BAR-01-T-IN-403-T	Classroom Restroom 403 Sink	5/27/2021	647	<5.00
46	BAR-01-HA-BY-403-BF	Bottle Filler by 403	5/27/2021	648	12.7
47	BAR-01-CR-IN-402-T	Classroom 402 Sink	5/27/2021	648	<5.00
48	BAR-01-CR-IN-404-T	Classroom 404 Sink	5/27/2021	648	<5.00
49	BAR-01-CR-IN-405-T	Classroom 405 Sink	5/27/2021	647	<5.00
50	BAR-01-CR-IN-406-T	Classroom 406 Sink	5/28/2021	501	<5.00
51	BAR-01-CR-IN-407-T	Classroom 407 Sink	5/28/2021	502	<5.00
52	BAR-01-CR-IN-408-T	Classroom 408 Sink	5/27/2021	648	<5.00
53	BAR-01-CR-IN-409-T	Classroom 409 Sink	5/27/2021	649	<5.00
54	BAR-01-LIB-IN-501-T	Library Office 501 Sink	5/27/2021	649	<5.00
55	BAR-01-T-IN-501-T	Library Restroom 501 Sink	5/27/2021	650	<5.00
56	BAR-01-CR-IN-502-T	Library Restroom 502 Sink	5/27/2021	652	12.5
57	BAR-01-CR-IN-503-T	Library Restroom 503 Sink	5/27/2021	653	<5.00
58	BAR-01-T-IN-101C-T	Restroom 101C Sink, Retest	6/11/2021	531	14.8
59	BAR-01-KIT-IN-106-T1	Kitchen 106 Sink 1, Retest	6/11/2021	534	<5.00
60	BAR-01-EXT-BY-606-HB	Ext by Classroom 606 Hose Bib, Retest	6/11/2021	537	36.5
61	BAR-01-CR-IN-120-T	Office 120 Sink, Retest	6/11/2021	539	31.9
62	BAR-01-T-IN-120-T	Office Restroom 120 Sink, Retest	6/11/2021	540	54.6

Fred W. Hill Elementary School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	FWH-01-T-IN-119-T	Kitchen Restroom 119 Sink	5/28/2021	514	<5.00
2	FWH-01-KIT-IN-119-PF1	Kitchen 119 Pot Filler 1	5/28/2021	514	18.4
3	FWH-01-KIT-IN-119-PF2	Kitchen 119 Pot Filler 2	5/28/2021	515	5.95
4	FWH-01-KIT-IN-119-T1	Kitchen 119 Sink 1	5/28/2021	516	<5.00
5	FWH-01-KIT-IN-119-IM	Kitchen 119 Ice Machine	5/28/2021	517	<5.00
6	FWH-01-KIT-IN-119-T2	Kitchen 119 Sink 2	5/28/2021	518	5.23
7	FWH-01-KIT-IN-119-SP	Kitchen 119 Sprayer	5/28/2021	519	<5.00
8	FWH-01-T-IN-108-T	Serving Area Restroom 108 Sink	5/28/2021	521	<5.00
9	FWH-01-SRV-IN-108-T	Serving Area 108 Sink	5/28/2021	522	<5.00
10	FWH-01-CR-IN-109-T	Classroom 109 Sink	5/28/2021	530	<5.00
11	FWH-01-T-IN-109-T	Classroom Restroom 109 Sink	5/28/2021	531	<5.00
12	FWH-01-CR-IN-107-T	Classroom 107 Sink	5/28/2021	531	<5.00
13	FWH-01-CR-IN-106-T	Classroom 106 Sink	5/28/2021	535	<5.00
14	FWH-01-CR-IN-105-T	Classroom 105 Sink	5/28/2021	535	<5.00
15	FWH-01-CR-IN-104-T	Classroom 104 Sink	5/28/2021	535	<5.00
16	FWH-01-CR-IN-103-T	Classroom 103 Sink	5/28/2021	536	<5.00
17	FWH-01-CR-IN-102-T	Classroom 102 Sink	5/28/2021	536	<5.00
18	FWH-01-CR-IN-101-T	Classroom 101 Sink	5/28/2021	537	<5.00
19	FWH-01-CR-IN-100-T	Classroom 100 Sink	5/28/2021	539	<5.00
20	FWH-01-T-IN-123-T	Restroom 123 Sink	5/28/2021	539	<5.00
21	FWH-01-T-IN-125-T	Restroom 125 Sink	5/28/2021	534	<5.00
22	FWH-01-HA-BY-127-BF	Bottle Filler by Room 127	5/28/2021	534	<5.00
23	FWH-01-T-IN-130A-T	Restroom 130A Sink	5/28/2021	535	<5.00
24	FWH-01-RM-IN-130-T	Room 130 Sink	5/28/2021	539	Lost
25	FWH-01-RM-IN-130-CT	Room 130 Coffee Line	5/28/2021	539	<10.00
26	FWH-01-LR-IN-133-T	Locker Room 133 Sink	5/28/2021	539	<5.00
27	FWH-01-LR-IN-135-T	Locker Room 135 Sink	5/28/2021	541	<5.00
28	FWH-01-T-IN-150-T	Office Restroom 150 Sink	5/28/2021	541	<5.00
29	FWH-01-HA-BY-162-BF	Bottle Filler by Restroom 162	5/28/2021	544	20.4
30	FWH-01-T-IN-162-T2	Restroom 162 Right Sink	5/28/2021	546	42.7
31	FWH-01-T-IN-164-T1	Restroom 164 Left Sink	5/28/2021	546	<5.00
32	FWH-01-T-IN-162-T1	Restroom 162 Left Sink	5/28/2021	546	<5.00
33	FWH-01-T-IN-164-T2	Restroom 164 Right Sink	5/28/2021	547	<5.00
34	FWH-01-NO-IN-166-T	Nurse's Office 166 Sink	5/28/2021	548	<5.00
35	FWH-01-NO-IN-166B-T	Nurse's Office Exam Room 166B Sink	5/28/2021	549	<5.00
36	FWH-01-T-IN-166C-T	Nurse's Office Restroom 166C Sink	5/28/2021	550	<5.00
37	FWH-01-NO-IN-168-T	Nurse's Office 168 Sink	5/28/2021	550	<5.00
38	FWH-01-T-IN-170-T	Classroom Restroom 170 Sink	5/28/2021	551	<5.00
39	FWH-01-CR-IN-171-T	Classroom 171 Sink	5/28/2021	552	5.96
40	FWH-01-CR-IN-174-T	Classroom 174 Sink	5/28/2021	552	<5.00
41	FWH-01-CR-IN-173-T	Classroom 173 Sink	5/28/2021	553	<5.00
42	FWH-01-CR-IN-176-T	Classroom 176 Sink	5/28/2021	553	<5.00

Fred W. Hill Elementary School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
43	FWH-01-CR-IN-175-T	Classroom 175 Sink	5/28/2021	554	<5.00
44	FWH-01-CR-IN-178-T	Classroom 178 Sink	5/28/2021	554	<5.00
45	FWH-01-CR-IN-177-T	Classroom 177 Sink	5/28/2021	554	<5.00
46	FWH-01-CR-IN-180-T	Classroom 180 Sink	5/28/2021	555	<5.00
47	FWH-01-CR-IN-179-T	Classroom 179 Sink	5/28/2021	556	<5.00
48	FWH-02-T-IN-227-T	Library Restroom 227 Sink	5/28/2021	559	<5.00
49	FWH-02-T-IN-227B-T	Library 227B Sink	5/28/2021	559	<5.00
50	FWH-02-HA-BY-223-BF	Bottle Filler by 223	5/28/2021	601	<5.00
51	FWH-02-FR-IN-223-T	Faculty Room 223 Sink	5/28/2021	602	<5.00
52	FWH-02-CR-IN-213-T2	Classroom 213 Sink 2	5/28/2021	603	6.72
53	FWH-02-CR-IN-211-T1	Classroom 211 Sink 1	5/28/2021	604	<5.00
54	FWH-02-CR-IN-211-T2	Classroom 311 Sink 2	5/28/2021	604	<5.00
55	FWH-02-CR-IN-208-T	Classroom 208 Sink	5/28/2021	604	<5.00
56	FWH-02-CR-IN-209-T	Classroom 209 Sink	5/28/2021	605	<5.00
57	FWH-02-CR-IN-206-T	Classroom 206 Sink	5/28/2021	605	<5.00
58	FWH-02-CR-IN-207-T	Classroom 207 Sink	5/28/2021	606	<5.00
59	FWH-02-CR-IN-204-T	Classroom 204 Sink	5/28/2021	607	<5.00
60	FWH-02-CR-IN-205-T	Classroom 205 Sink	5/28/2021	608	<5.00
61	FWH-02-CR-IN-202-T	Classroom 202 Sink	5/28/2021	608	<5.00
62	FWH-02-CR-IN-203-T	Classroom 203 Sink	5/28/2021	609	<5.00
63	FWH-02-CR-IN-200-T	Classroom 200 Sink	5/28/2021	609	<5.00
64	FWH-02-CR-IN-201-T	Classroom 201 Sink	5/28/2021	610	<5.00
65	FWH-02-T-IN-244-T	Classroom 244 Sink	5/28/2021	610	<5.00
66	FWH-02-T-IN-240-T	Classroom 240 Sink	5/28/2021	611	<5.00
67	FWH-02-CR-IN-271-T	Classroom 271 Sink	5/28/2021	612	<5.00
68	FWH-02-T-IN-270-T	Classroom 270 Sink	5/28/2021	613	<5.00
69	FWH-02-CR-IN-273-T	Classroom 273 Sink	5/28/2021	614	<5.00
70	FWH-02-CR-IN-274-T	Classroom 274 Sink	5/28/2021	615	<5.00
71	FWH-02-CR-IN-275-T	Classroom 275 Sink	5/28/2021	616	<5.00
72	FWH-02-CR-IN-276-T	Classroom 276 Sink	5/28/2021	617	<5.00
73	FWH-02-CR-IN-277-T	Classroom 277 Sink	5/28/2021	617	6.11
74	FWH-02-CR-IN-278-T	Classroom 278 Sink	5/28/2021	618	<5.00
75	FWH-02-CR-IN-279-T	Classroom 279 Sink	5/28/2021	618	<5.00
76	FWH-02-CR-IN-280-T	Classroom 280 Sink	5/28/2021	619	<5.00
77	FWH-01-KIT-IN-119-PF1	Kitchen 119 Pot Filler 1, Retest	6/11/2021	450	17.8
78	FWH-01-RM-IN-130-T	Room 130 Sink, Retest	6/11/2021	452	<5.00
79	FWH-01-HA-BY-162-BF	Bottle Filler by Restroom 162, Retest	6/11/2021	454	<5.00
80	FWH-01-T-IN-162-T2	Restroom 162 Right Sink, Retest	6/11/2021	455	<5.00

A.D. Oliver Middle School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	OMS-01-CO-IN-030A-T	Custodian's Office Restroom 030A	5/27/2021	514	<5.00
2	OMS-01-CR-IN-033-T	Classroom 033 Utility Sink	5/27/2021	515	5.98
3	OMS-01-CR-IN-035-T	Classroom 035 Utility Sink	5/27/2021	516	<5.00
4	OMS-01-CR-IN-037-T	Classroom 037 Sink	5/27/2021	516	Lost
5	OMS-01-CR-IN-047-T7	Classroom 047 Sink 7	5/27/2021	517	7.14
6	OMS-01-CR-IN-047-T6	Classroom 047 Sink 6	5/27/2021	517	7.04
7	OMS-01-CR-IN-047-T1	Classroom 047 Sink 1	5/27/2021	517	6.96
8	OMS-01-CR-IN-047-T5	Classroom 047 Sink 5	5/27/2021	518	Lost
9	OMS-01-CR-IN-047-T2	Classroom 047 Sink 2	5/27/2021	518	<5.00
10	OMS-01-CR-IN-047-T4	Classroom 047 Sink 4	5/27/2021	518	Lost
11	OMS-01-CR-IN-047-T3	Classroom 047 Sink 3	5/27/2021	519	<5.00
12	OMS-01-CR-IN-048-T	Classroom 48 Sink	5/27/2021	521	<5.00
13	OMS-01-HA-BY-044-BF	Bottle Filler by Restroom 044	5/27/2021	524	<5.00
14	OMS-01-KIT-IN-069-T1	Kitchen 069 Prep Sink 1	5/27/2021	525	<5.00
15	OMS-01-KIT-IN-069-PF1	Kitchen 069 Pot Filler 1	5/27/2021	525	<5.00
16	OMS-01-KIT-IN-069-PF2	Kitchen 069 Pot Filler 2	5/27/2021	525	<5.00
17	OMS-01-KIT-IN-069-PF3	Kitchen 069 Pot Filler 3	5/27/2021	525	<5.00
18	OMS-01-KIT-IN-069-T2	Kitchen 069 Prep Sink 2	5/27/2021	526	<5.00
19	OMS-01-KIT-IN-069-T3	Kitchen 069 Prep Sink 3	5/27/2021	526	<5.00
20	OMS-01-KIT-IN-069-IM	Kitchen 069 Ice Machine	5/27/2021	527	<5.00
21	OMS-01-FSO-IN-062-T	FSO 062 Sink	5/27/2021	527	<5.00
22	OMS-01-BLR-IN-081-MS	Boy's Locker Room 081 Closet Mop Sink	5/27/2021		No Access
23	OMS-01-GO-IN-082-T	Gym Office 082 Restroom Sink	5/27/2021	529	9.64
24	OMS-01-CON-IN-084-T	Concessions 084 Sink	5/27/2021	532	<5.00
25	OMS-01-HA-BY-089-BF	Bottle Filler by Weight Room 089	5/27/2021	533	<5.00
26	OMS-01-CUS-IN-099-MS	Custodial Room 099 Mop Sink	5/27/2021	535	Lost
27	OMS-01-CUS-IN-099-IM	Custodial Room 099 Ice Machine	5/27/2021	537	<5.00
28	OMS-01-CR-IN-007-T	Classroom 007 Sink	5/27/2021	539	Lost
29	OMS-02-MUS-IN-128-T	Band Room 128 Sink	5/27/2021	542	<5.00
30	OMS-03-MT-IN-116-T	Auditorium 116 Men's Toilet	5/27/2021	543	<5.00
31	OMS-03-WT-IN-116-T	Auditorium 116 Women's Toilet	5/27/2021	543	<5.00
32	OMS-02-HA-BY-160-BF	Bottle Filler by Room 160	5/27/2021	545	<5.00
33	OMS-02-CR-IN-153-T1	Classroom 153 Left Sink	5/27/2021	546	<5.00
34	OMS-02-CR-IN-153-T2	Classroom 153 Right Sink	5/27/2021	546	28.5
35	OMS-02-FAC-IN-150-T	Faculty Room 150 Sink	5/27/2021	547	<5.00
36	OMS-02-FAC-IN-150-CT	Faculty Room 150 Coffee Line	5/27/2021	548	<10.0
37	OMS-03-HA-BY-127-BF	Bottle Filler by Restroom 127	5/27/2021	550	<5.00
38	OMS-03-NO-IN-112-T	Nurse's Office 112 Sink	5/27/2021	551	<5.00
39	OMS-03-T-IN-112-T	Nurse's Office 112 Restroom Sink	5/27/2021	551	<5.00

A.D. Oliver Middle School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
40	OMS-03-GO-IN-101C-T	Gym Office 101C Sink	5/27/2021	543	18.1
41	OMS-03-GO-IN-101A-T	Gym Office 101A Sink	5/27/2021	544	41.5
42	OMS-04-HA-BY-260-BF	Bottle Filler by Faculty Room 260	5/27/2021	550	<5.00
43	OMS-05-HA-BY-227-BF	Bottle Filler by Restroom 227	5/27/2021	552	<5.00
44	OMS-05-FAC-IN-221-T	Faculty Room 221 Sink	5/27/2021	554	<5.00
45	OMS-05-FAC-IN-221-CT	Faculty Room 221 Coffee Line	5/27/2021	559	<5.00
46	OMS-05-LIB-IN-228-T	Library Room 228 Sink	5/27/2021	600	7.7
47	OMS-06-HA-BY-327-BF	Bottle Filler by Restroom 327	5/27/2021	601	<5.00
48	OMS-01-CR-IN-037-T	Classroom 037 Sink, Retest	6/11/2021	432	6.28
49	OMS-01-CR-IN-047-T5	Classroom 047 Sink 5, Retest	6/11/2021	434	<5.00
50	OMS-01-CR-IN-047-T4	Classroom 047 Sink 4, Retest	6/11/2021	434	6.46
51	OMS-01-CUS-IN-099-MS	Custodial Room 099 Mop Sink, Retest	6/11/2021	438	6.06
52	OMS-01-CR-IN-007-T	Classroom 007 Sink, Retest	6/11/2021	441	<5.00
53	OMS-02-CR-IN-153-T2	Classroom 153 Right Sink, Retest	6/11/2021	442	36.5
54	OMS-03-GO-IN-101C-T	Gym Office 101C Sink, Retest	6/11/2021	444	21.7
55	OMS-03-GO-IN-101A-T	Gym Office 101A Sink, Retest	6/11/2021	445	41.7

Brockport High School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	BHS-00-T-IN-044-T	Restroom 044 Sink	5/26/2021	505	12.6
2	BHS-00-T-IN-046-T	Restroom 046 Sink	5/26/2021	506	14.4
3	BHS-00-T-IN-047-T	Restroom 047 Sink	5/26/2021	507	14.5
4	BHS-00-OFF-IN-022-T	Office 022 Sink	5/26/2021	508	<5.00
5	BHS-00-FIT-IN-020-BF	Bottle Filler in Weight Room	5/26/2021	509	<5.00
6	BHS-00-FIT-IN-020A-MS	Mop Sink in Weight Room Closet	5/26/2021	510	<5.00
7	BHS-00-FIT-IN-020A-IM	Ice Machine in Weight Room Closet	5/26/2021	512	<5.00
8	BHS-00-CR-IN-019-T	Classroom 019 Sink	5/26/2021	513	6.83
9	BHS-00-BT-IN-018B-T2	Boy's Restroom 018B Right Tap	5/26/2021	514	<5.00
10	BHS-00-GT-IN-018G-T1	Girl's Restroom 018G Left Tap	5/26/2021	514	<5.00
11	BHS-00-BT-IN-018B-T1	Boy's Restroom 018B Left Tap	5/26/2021	514	<5.00
12	BHS-00-GT-IN-018G-T2	Girl's Restroom 018G Right Tap	5/26/2021	515	<5.00
13	BHS-00-HA-BY-014-BF	Bottle Filler by 014	5/26/2021	517	<5.00
14	BHS-00-CR-IN-013-T	Classroom 013 Sink	5/26/2021	516	23.2
15	BHS-00-CR-IN-011-T	Classroom 011 Sink	5/26/2021	518	16.3
16	BHS-00-CR-IN-014-T	Classroom 014 Sink	5/26/2021	519	101
17	BHS-00-BR-IN-002-T	Break Room 002 Sink	5/26/2021	520	11.1
18	BHS-00-BR-IN-002-CT	Break Room 002 Coffee Line	5/26/2021	521	<5.00
19	BHS-01-BT-IN-138B-T1	Boy's Restroom 138B Left Tap	5/26/2021	528	<5.00
20	BHS-01-BT-IN-138B-T2	Boy's Restroom 138B Right Tap	5/26/2021	528	<5.00
21	BHS-01-GT-IN-138G-T	Girl's Restroom 138G Tap	5/26/2021	530	50.4
22	BHS-01-LR-IN-194-T	Laundry Room 194 Tap (Utility)	5/26/2021	532	<5.00
23	BHS-01-BLR-IN-135B-T	Boy's Locker Room 135B Tap	5/26/2021	532	<5.00
24	BHS-01-T-IN-137-T	Official's Restroom 137 Tap	5/26/2021	535	17.4
25	BHS-01-GLR-IN-135G-T	Girl's Locker Room 135G Tap	5/26/2021	535	<5.00
26	BHS-01-HA-BY-134-BF	Bottle Filler by 134	5/26/2021	529	<5.00
27	BHS-01-BLR-IN-132-T	Boy's Locker Room 132 Tap	5/26/2021	536	7.74
28	BHS-01-GLR-IN-129-T1	Girl's Locker Room 129 Tap 1			No Access
29	BHS-01-GLR-IN-129-T2	Girl's Locker Room 129 Tap 2			No Access
30	BHS-01-GLR-IN-129-T3	Girl's Locker Room 129 Tap 3			No Access
31	BHS-01-T-IN-196A-T	Coach's Office Restroom 196A Sink	5/26/2021	538	7.3
32	BHS-01-T-IN-196B-T	Coach's Office Restroom 196B Sink	5/26/2021	539	6.39
33	BHS-01-GYM-IN-196E-BF	Eastern Bottle Filler in Gym 196	5/26/2021	541	<5.00
34	BHS-01-CR-IN-193-T	Classroom 193 Tap (Utility)	5/26/2021	543	82.4
35	BHS-01-CR-IN-192-T	Classroom 192 Tap (Utility)	5/26/2021	548	<5.00

Brockport High School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
36	BHS-01-CR-IN-190-T	Classroom 190 Tap (Utility)	5/26/2021	549	<5.00
37	BHS-01-CR-IN-189-T	Classroom 189 Tap (Utility)	5/26/2021	551	<5.00
38	BHS-01-STG-IN-180-T	Stage Changing Room 180 Sink	5/26/2021	612	20.1
39	BHS-01-T-IN-181Q-T	Music Wing Restroom Sink	5/26/2021	551	<5.00
40	BHS-01-STOR-IN-181F-T	Music Wing Storage Room Sink	5/26/2021	552	<5.00
41	BHS-01-BLR-IN-195-T	Boy's Locker Room 195 Sink	5/26/2021	556	7.51
42	BHS-01-GLR-IN-197-T1	Girl's Locker Room 197 Left Sink	5/26/2021	600	55.3
43	BHS-01-GLR-IN-197-T2	Girl's Locker Room 197 Right Sink	5/26/2021		Not Working
44	BHS-01-RM-IN-199-MS	Mop Sink in Room 199	5/26/2021	603	<5.00
45	BHS-01-T-IN-196E-T	Coach's Office Restroom 196E Sink	5/26/2021	604	<5.00
46	BHS-01-GYM-IN-196W-BF	Western Bottle Filler in Gym 196	5/26/2021	604	<5.00
47	BHS-01-CR-IN-198-T	Classroom 198 Sink	5/26/2021	606	8.02
48	BHS-01-NO-IN-175D-T	Nurse's Exam Room D Sink	5/26/2021	607	Lost
49	BHS-01-NO-IN-175C-T	Nurse's Exam Room C Sink	5/26/2021	607	21.4
50	BHS-01-NO-IN-175B-T	Nurse's Exam Room B Sink	5/26/2021	607	<5.00
51	BHS-01-NO-IN-175A-T	Nurse's Exam Room A Sink	5/26/2021	608	<5.00
52	BHS-01-CO-IN-176-T	Custodian Office 176 Sink	5/26/2021	609	<5.00
53	BHS-01-HA-BY-167-BF	Bottle Filler by 167	5/26/2021	616	<5.00
54	BHS-01-CR-IN-167-T	Classroom 167 Tap	5/26/2021	615	<5.00
55	BHS-01-MT-IN-166A-T	Men's Toilet 166A Sink	5/26/2021	620	<5.00
56	BHS-01-WT-IN-166B-T	Women's Toilet 166B Sink	5/26/2021	620	<5.00
57	BHS-01-KIT-IN-166-T	Kitchenette 166 Sink	5/26/2021	621	<5.00
58	BHS-01-KIT-IN-166-CT	Kitchenette 166 Coffee Line	5/26/2021	621	<5.00
59	BHS-01-T-IN-165D-T	Restroom 165D Sink	5/26/2021	615	<5.00
60	BHS-01-T-IN-165C-T	Restroom 165C Sink	5/26/2021	616	<5.00
61	BHS-01-T-IN-165B-T	Restroom 165B Sink	5/26/2021	501	<5.00
62	BHS-01-T-IN-165A-T	Restroom 165A Sink	5/26/2021	618	<5.00
63	BHS-01-BR-IN-139-T	Break Room 139 Sink	5/26/2021	626	<5.00
64	BHS-01-BR-IN-139-CT	Break Room 139 Coffee Line	5/26/2021	627	<5.00
65	BHS-01-KIT-IN-140-T5	Kitchen 140 Sink 5 - Handwash by Dishwash	5/27/2021	503	<5.00
66	BHS-01-KIT-IN-140-T1	Kitchen 140 Sink 1 - Handwash by Lockers	5/27/2021	503	<5.00
67	BHS-01-KIT-IN-140-T2	Kitchen 140 Sink 2 - Prep 1	5/27/2021	503	<5.00
68	BHS-01-KIT-IN-140-SP	Kitchen 140 Sprayer	5/27/2021	503	<5.00
69	BHS-01-KIT-IN-140-PF1	Kitchen 140 Pot Filler 1	5/27/2021	504	<5.00
70	BHS-01-KIT-IN-140-PF2	Kitchen 140 Pot Filler 2	5/27/2021	504	<5.00
71	BHS-01-KIT-IN-140-PF3	Kitchen 140 Pot Filler 3	5/27/2021	504	12.4

Brockport High School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
72	BHS-01-KIT-IN-140-T3	Kitchen 140 Sink 3 - Prep 2	5/27/2021	505	<5.00
73	BHS-01-KIT-IN-140-T4	Kitchen 140 Sink 4 - Handwash by Prep 2	5/27/2021	506	<5.00
74	BHS-01-KIT-IN-140-IM	Kitchen 140 Ice Machine	5/26/2021	630	<5.00
75	BHS-01-BR-IN-114-CT	Break Room 114 Coffee Line	5/26/2021	634	<5.00
76	BHS-01-HA-BY-113-BF	Bottle Filler by 113	5/26/2021	640	<5.00
77	BHS-01-BT-IN-112B-T2	Boy's Restroom 112B Right Sink	5/26/2021	649	<5.00
78	BHS-01-GT-IN-112G-T1	Girl's Restroom 112G Left Sink	5/26/2021	649	<5.00
79	BHS-01-BT-IN-112B-T1	Boy's Restroom 112B Left Sink	5/26/2021	649	<5.00
80	BHS-01-GT-IN-112G-T2	Girl's Restroom 112G Right Sink	5/26/2021	650	<5.00
81	BHS-01-MT-IN-109-T	Men's Toilet 109 Sink	5/26/2021	652	<5.00
82	BHS-01-WT-IN-107-T	Women's Toilet 107 Sink	5/26/2021	652	<5.00
83	BHS-02-BT-IN-212B-T2	Boy's Restroom 212B Right Sink	5/26/2021	654	<5.00
84	BHS-02-GT-IN-212G-T1	Girl's Restroom 212G Left Sink	5/26/2021	654	<5.00
85	BHS-02-BT-IN-212B-T1	Boy's Restroom 212B Left Sink	5/26/2021	654	<5.00
86	BHS-02-GT-IN-212G-T2	Girl's Restroom 212G Right Sink	5/26/2021	655	<5.00
87	BHS-02-HA-BY-211-BF	Bottle Filler by 211	5/26/2021	656	<5.00
88	BHS-02-T-IN-265D-T	Restroom 265D Sink	5/26/2021	658	<5.00
89	BHS-02-T-IN-265C-T	Restroom 265C Sink	5/26/2021	659	<5.00
90	BHS-02-T-IN-265B-T	Restroom 265B Sink	5/26/2021	659	<5.00
91	BHS-02-T-IN-265A-T	Restroom 265A Sink	5/26/2021	700	<5.00
92	BHS-02-HA-BY-267-BF	Bottle Filler by 267	5/26/2021	701	<5.00
93	BHS-00-CR-IN-013-T	Classroom 013 Sink, Retest	6/11/2021	601	30.4
94	BHS-00-CR-IN-011-T	Classroom 011 Sink, Retest	6/11/2021	601	9.67
95	BHS-00-CR-IN-014-T	Classroom 014 Sink, Retest	6/11/2021	602	29.9
96	BHS-01-BT-IN-138G-T	Girl's Restroom 138G Tap, Retest	6/11/2021	604	55.1
97	BHS-01-T-IN-137-T	Official's Restroom 137 Tap, Retest	6/11/2021	606	11.2
98	BHS-01-STG-IN-180-T	Stage Changing Room 180 Sink, Retest	6/11/2021	608	11.4
99	BHS-01-GLR-IN-197-T1	Girl's Locker Room 197 Left Sink, Retest	6/11/2021	610	25.4
100	BHS-01-GLR-IN-197-T2	Girl's Locker Room 197 Right Sink	6/11/2021	611	37.2

Brockport High School					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
101	BHS-01-NO-IN-175D-T	Nurse's Exam Room D Sink, Retest	6/11/2021	613	22.8
102	BHS-01-NO-IN-175C-T	Nurse's Exam Room C Sink, Retest	6/11/2021	613	54.4

Transportation Facility					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	BUS-01-LOB-IN-15-DF1	Lobby 15 Drinking Fountain 1	5/28/2021	500	<5.00
2	BUS-01-LOB-IN-15-DF2	Lobby 15 Drinking Fountain 2	5/28/2021	500	<5.00
3	BUS-01-MPR-IN-19-T	Multi-Purpose Room 19 Sink	5/28/2021	501	<5.00
4	BUS-01-MPR-IN-19-CT	Multi-Purpose Room 19 Coffee Line	5/28/2021	504	<5.00
5	BUS-01-MNT-IN-27-DF	Maintenance Bays 27 Drinking Fountain	5/28/2021	505	<5.00
6	BUS-01-MEC-IN-23-T	Mechanic's Room 23 Sink	5/28/2021	506	<5.00

Administration Building					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	ADM-01-KIT-IN-8-T	Kitchen 8 Sink	5/28/2021	515	<5.00
2	ADM-01-KIT-IN-8-CT	Kitchen 8 Coffee Line	5/28/2021	516	<10.0
3	ADM-01-KIT-IN-8-CP	Kitchen Coffee Pot	5/28/2021	517	<5.00
4	ADM-01-HA-BY-17-BF	Bottle Filler by 17	5/28/2021	520	<5.00
5	ADM-01-EXT-BY-22-HB	Hose Bib by 22	5/28/2021	521	16.6

TTC Building					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	TTC-01-KIT-IN-5-T	Kitchen 5 Sink	5/28/2021	524	<5.00
2	TTC-01-KIT-IN-23-T	Kitchenette 23 Sink	5/28/2021	525	<5.00
3	TTC-01-KIT-IN-23-CT	Kitchenette 23 Coffee Line	5/28/2021	525	<10.0
4	TTC-01-HA-BY-27-DF1	Left Drinking Fountain by Men's 27	5/28/2021	527	<5.00
5	TTC-01-HA-BY-27-DF2	Right Drinking Fountain by Men's 27	5/28/2021	527	<5.00
6	TTC-01-GT-IN-25-T1	Girl's Restroom Sink 1	6/11/2021	506	<5.00
7	TTC-01-GT-IN-25-T2	Girl's Restroom Sink 2	6/11/2021	507	<5.00
8	TTC-01-GT-IN-25-T3	Girl's Restroom Sink 3	6/11/2021	507	<5.00
9	TTC-01-BT-IN-27-T3	Boy's Restroom Sink 3	6/11/2021	509	<5.00
10	TTC-01-BT-IN-27-T2	Boy's Restroom Sink 2	6/11/2021	509	<5.00
11	TTC-01-BT-IN-27-T1	Boy's Restroom Sink 1	6/11/2021	510	<5.00

Operations Building					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	OPS-01-KIT-IN-OPS-T	Operations Kitchen Sink	6/11/2021	615	<5.00
2	OPS-01-HA-IN-OPS-BF	Operations Bottle Filler	6/11/2021	615	<5.00
3	OPS-01-SHP-IN-OPS-T	Operations Shop Sink	6/11/2021	615	<5.00
4	OPS-01-KIT-IN-OPS-CT	Operations Kitchen Coffee Line	6/11/2021	615	<5.00

Maintenance Building					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	MNT-01-KIT-IN-MNT-T	Grounds Kitchen Sink	6/11/2021	618	<5.00
2	MNT-01-HA-IN-MNT-DF	Grounds Drinking Fountain	6/11/2021	618	<5.00
3	MNT-01-KITOINOMNT-CT	Grounds Kitchen Coffee Line	6/11/2021	619	<5.00

Brockport High School Concessions					
Testing Order	New Identification Code	Description	Date Sampled	Time Sampled	Results (ug/L)
1	CON-01-KIT-IN-CON-MS	Concessions Mop Sink	6/11/2021	621	<5.00
2	CON-01-KIT-IN-CON-T1	Conc. Kitchen Sink 1	6/11/2021	622	<5.00
3	CON-01-KIT-IN-CON-T2	Conc. Kitchen Sink 2	6/11/2021	622	<5.00
4	CON-01-KIT-IN-CON-T3	Conc. Kitchen Sink 3	6/11/2021	622	<5.00
5	CON-01-EXT-BY-CON-HB1	Hose Bib by Bathrooms	6/11/2021	624	19.7
6	CON-01-EXT-BY-CON-HB2	Hose Bib by Serving Window	6/11/2021	624	59.9
7	CON-01-EXT-BY-CON-HL1	Field Hose Line, East Side	6/11/2021	626	24.2
8	CON-01-EXT-BY-CON-HL2	Field Hose Line, West Side	6/11/2021	626	62.5

Appendix B

Laboratory Analytical Results



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422341

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Ginther Elementary School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422341-001	T-IN-520-T	Restroom 520 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-002	T-IN-522-T	Restroom 522 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	10.9	5.00	µg/L	06/04/21	JL
422341-003	RM-IN-512-T	Room 512 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-004	HA-BY-512-BF	Bottle Filler By 512					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-005	KIT-IN-504-SPRAYE	Kitchen 504 Sprayer					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-006	KIT-IN-504-T	Kitchen 504 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-007	RM-IN-511-T1	Riin 511 Sink 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-008	RM-IN-511-T2	Riin 511 Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-009	RM-IN-511-T3	Riin 511 Sink 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-010	T-IN-509-T	Restroom 509 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-011	T-IN-505-T	Restroom 505 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	19.7	5.00	µg/L	06/04/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422341

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Ginther Elementary School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422341-012	T-IN-503-T	Restroom 503 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422341-013	FR-IN-100-T	Faculty Room 100 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422341-014	FR-IN-100-CT	Faculty Room 100 Coffee					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <10.0 10.0 µg/L 06/08/21 JL							
422341-015	T-IN-100-T	Faculty Room 100 Restroom					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422341-016	HA-BY-101-BF	Bottle Filler Main Office					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422341-017	T-IN-101-T	Main Office 101 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422341-018	OF-IN-101C-T	Main Office 101C Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422341-019	OF-IN-101E-T	Main Office 101E Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422341-020	T-BY-107-T	Restroom 107 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422341-021	RM-IN-106-T	Conference Room 106 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422341-022	CR-IN-108-T	Classroom 108 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422341

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Ginther Elementary School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422341-023	T-IN-108-T	Classroom 108 Restroom					
Metals Analysis							
Lead							
422341-024	CR-IN-109-T	Classroom 109 Sink					
Metals Analysis							
Lead							
422341-025	CR-IN-110-T	Classroom 110 Sink					
Metals Analysis							
Lead							
422341-026	CR-IN-111-T	Classroom 111 Sink					
Metals Analysis							
Lead							
422341-027	CR-IN-112-T	Classroom 112 Sink					
Metals Analysis							
Lead							
422341-028	CR-IN-113-T	Classroom 113 Sink					
Metals Analysis							
Lead							
422341-029	CR-IN-114-T	Classroom 114 Sink					
Metals Analysis							
Lead							
422341-030	CR-IN-115-T	Classroom 115 Sink					
Metals Analysis							
Lead							
422341-031	CR-IN-116-T	Classroom 116 Sink					
Metals Analysis							
Lead							
422341-032	CR-IN-400-T	Classroom 400 Sink					
Metals Analysis							
Lead							
422341-033	CR-IN-401-T	Classroom 401 Sink					
Metals Analysis							
Lead							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422341

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Ginther Elementary School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422341-034	CR-IN-402-T	Classroom 402 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-035	CR-IN-403-T	Classroom 403 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.37	5.00	µg/L	06/04/21	JL
422341-036	CR-IN-404-T	Classroom 404 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-037	CR-IN-405-T	Classroom 405 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-039	T2-IN-316-T	Library 316 Right					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-040	T1-IN-316-T	Library 316 Left Restroom					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-041	LIB-IN-316A-T	Library 316A Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2					
Sample not received.							
422341-042	CR-IN-321-T	Classroom 321 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2					
Sample not received.							
422341-043	CR-IN-314-T	Classroom 314 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2					
Sample not received.							
422341-044	CR-IN-312-T	Classroom 312 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422341

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Ginther Elementary School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422341-045	CR-IN-310-T	Classroom 310 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-046	T-IN-309A-T	Restroom 309A Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-047	CR-IN-308-T	Classroom 308 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	15.4	5.00	µg/L	06/04/21	JL
422341-048	T-IN-303-T	Restroom 303 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-049	CR-IN-200-T	Classroom 200 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	JL
422341-050	CR-IN-201-T	Classroom 201 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-051	CR-IN-202-T	Classroom 202 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-052	CR-IN-203-T	Classroom 203 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-053	CR-IN-204-T	Classroom 204 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-054	CR-IN-205-T	Classroom 205 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422341-055	CR-IN-206-T	Classroom 206 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422341

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Ginther Elementary School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID Method	Location Result	RL*	Units	Analysis Date	Analyst
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL

422341-06/09/21 04:45 PM

Reviewed By:

Analyst

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State	Certificate Number		
New York	ELAP 63556		
Virginia	VELAP 11259		

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422289

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Barclay Elementary School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422289-001	T-IN-101-T	Restroom 101 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	7.69	5.00	µg/L	06/05/21	HI
422289-002	HA-BY-100-BF	BF By Restroom 100					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422289-003	T-IN-101C-T	Restroom 101C Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	24.5	5.00	µg/L	06/05/21	HI
422289-004	KIT-IN-106-T1	Kitchen 106 Sink 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	20.7	5.00	µg/L	06/05/21	HI
422289-005	KIT-IN-106-T2	Kitchen 106 Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422289-006	KIT-IN-106-T3	Kitchen 106 Sink 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.10	5.00	µg/L	06/05/21	HI
422289-007	FAC-IN-108-T	Faculty Room 108 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422289-008	FAC-IN-108-CT	Faculty Room 108 Coffee					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422289-009	T-IN-105-T	Restroom 105 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	11.2	5.00	µg/L	06/05/21	HI
422289-010	MT-IN-200M-T	Men's Restroom 200M Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	7.07	5.00	µg/L	06/05/21	HI
422289-011	WT-IN-200W-T	Women's Restroom 200W					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422289

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Barclay Elementary School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422289-012	T-IN-204-T	Classroom 204 Restroom					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-013	T-IN-205-T	Classroom 205 Restroom					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-014	EXT-BY-103-HB	Exterior By Gym 103 Hose					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-015	CR-IN-601-T	Classroom 601 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-016	CR-IN-602-T	Classroom 602 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-017	CR-IN-603-T	Classroom 603 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-018	CR-IN-604-T	Classroom 604 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-019	CR-IN-605-T	Classroom 605 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-020	CR-IN-606-T	Classroom 606 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-021	T-IN-606-T	Classroom Restroom 606					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-022	EXT-BY-606-HB	Bose Bib By Classroom 606					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 22.3 5.00 µg/L 06/05/21 HI							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422289

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Barclay Elementary School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422289-023	CR-IN-607-T	Classroom 607 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-024	T-IN-607-T	Classroom Restroom 607					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 8.50 5.00 µg/L 06/05/21 HI							
422289-025	CR-IN-609-T	Classroom 609 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-026	EXT-BY-609-HB	Exterior By Classroom 609					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 9.58 5.00 µg/L 06/05/21 HI							
422289-027	CR-IN-610-T	Classroom 610 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-028	T-IN-611-T	Restroom 611 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-029	CR-IN-612-T	Classroom 612 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-030	CR-IN-613-T	Classroom 613 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422289-031	CR-IN-614-T	Classroom 614 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/07/21 JL							
422289-032	CR-IN-615-T	Classroom 615 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/07/21 JL							
422289-033	NO-IN-115-T	Nurse's Office 115 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/07/21 JL							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422289

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Barclay Elementary School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422289-034	NP-IN-115A-T	Nurse's Office Restroom					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/07/21 JL							
422289-035	CR-IN-302-T	Classroom 302 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 5.49 5.00 µg/L 06/07/21 JL							
422289-036	CR-IN-304-T	Classroom 304 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 6.43 5.00 µg/L 06/07/21 JL							
422289-037	CR-IN-305-T	Classroom 305 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 14.5 5.00 µg/L 06/07/21 JL							
422289-038	CR-IN-306-T	Classroom 306 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 6.35 5.00 µg/L 06/07/21 JL							
422289-039	CR-IN-307-T	Classroom 307 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/07/21 JL							
422289-040	CR-IN-308-T	Classroom 308 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 13.7 5.00 µg/L 06/07/21 JL							
422289-041	CR-IN-309-T	Classroom 309 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 8.19 5.00 µg/L 06/07/21 JL							
422289-042	CR-IN-120-T	Office 120 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 32.5 5.00 µg/L 06/07/21 JL							
422289-043	T-IN-120-T	Office Restroom 120 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 63.6 10.0 µg/L 06/07/21 JL							
422289-044	T-IN-132-T	Classroom Restroom 132					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/07/21 JL							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422289

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Barclay Elementary School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422289-045	T-IN-403-T	Classroom Restroom 403					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422289-046	HA-BY-403-BF	BF By 403					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	12.7	5.00	µg/L	06/07/21	JL
422289-047	CR-IN-402-T	Classroom 402 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422289-048	CR-IN-404-T	Classroom 404 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422289-049	CR-IN-405-T	Classroom 405 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422289-050	CR-IN-406-T	Classroom 406 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422289-051	CR-IN-407-T	Classroom 407 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422289-052	CR-IN-408-T	Classroom 408 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422289-053	CR-IN-409-T	Classroom 409 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422289-054	LIB-IN-501-T	Library Office 501 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422289-055	T-IN-501-T	Library Restroom 501 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422289

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Barclay Elementary School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	12.5	5.00	µg/L	06/07/21	JL
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

422289-06/09/21 04:32 PM

Reviewed By:

Analyst

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State	Certificate Number		
New York	ELAP 63556		
Virginia	VELAP 11259		

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422328-001	FWH-01-T-IN-119-T	Kitchen Restrm 119 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-002	FWH-01-KIT-IN-119-	Kitchen 119 Pot Filler 1					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	18.4	5.00	µg/L	06/07/21	JL
422328-003	FWH-01-KIT-IN-119-	Kitchen 119 Pot Filler 2					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	5.95	5.00	µg/L	06/07/21	JL
422328-004	FWH-01-KIT-IN-119-	Kitchen 119 Sink 1					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-005	FWH-01-KIT-IN-119-I	Kitchen 119 Ice Machine					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-006	FWH-01-KIT-IN-119-	Kitchen 119 Sink 2					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	5.23	5.00	µg/L	06/07/21	JL
422328-007	FWH-01-KIT-IN-119-	Kitchen 119 Sprayer					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-008	FWH-01-T-IN-108-T	Serving Area Restroom 108					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-009	FWH-01-SRV-IN-108-	Serving Area 108 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-010	FWH-01-CR-IN-109-T	Classrm 109 Sink					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-011	FWH-01-T-IN-109-T	Classrm Restrm 109					
Metals Analysis							
Lead							
		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422328-012	FWH-01-CR-IN-107-T	Classrm 107 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-013	FWH-01-CR-IN-106-T	Classrm 106 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-014	FWH-01-CR-IN-105-T	Classrm 105 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-015	FWH-01-CR-IN-104-T	Classrm 104 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-016	FWH-01-CR-IN-103-T	Classrm 103 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-017	FWH-01-CR-IN-102-T	Classrm 102 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-018	FWH-01-CR-IN-101-T	Classrm 101 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-019	FWH-01-CR-IN-100-T	Classrm 100 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-020	FWH-01-T-IN-123-T	Restrm 123 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-021	FWH-01-T-IN-125-T	Restrm 125 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-022	FWH-01-HA-BY-127-	Bottle Filler By Rm 127					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422328-023	FWH-01-T-IN-130A-T	Restrm 130A Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-024	FWH-01-RM-IN-130-	Rm 130 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2					
Sample not received.							
422328-025	FWH-01-RM-IN-130-	Rm 130 Coffee Line					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<10.0	10.0	µg/L	06/08/21	JL
422328-026	FWH-01-LR-IN-133-T	Locker Rm 133 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-027	FWH-01-LR-IN-135-T	Locker Rm 135 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-028	FWH-01-T-IN-150-T	Office 155 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-029	FWH-01-HA-BY-162-	Bottle Filler By Restrm					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	20.4	5.00	µg/L	06/07/21	JL
422328-030	FWH-01-T-IN-162-T2	Restrm 162 Right Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	42.7	5.00	µg/L	06/07/21	JL
422328-031	FWH-01-T-IN-164-T1	Restrm 164 Left Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-032	FWH-01-T-IN-162-T1	Restrm 162 Left Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422328-033	FWH-01-T-IN-164-T2	Restrm 164 Right Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-034	FWH-01-NO-IN-166-T	Nurse's Office 166 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-035	FWH-01-NO-IN-166B	Nurse's Office Exam Rm					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-036	FWH-01-T-IN-166C-T	Nurse's Office Restrm					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-037	FWH-01-NO-IN-168-T	Nurse's Office 168 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-038	FWH-01-T-IN-170-T	Classrm Restrm 170 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-039	FWH-01-CR-IN-171-T	Classrm 171 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	5.96	5.00	µg/L	06/07/21	JL
422328-040	FWH-01-CR-IN-174-T	Classrm 174 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-041	FWH-01-CR-IN-173-T	Classrm 173 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-042	FWH-01-CR-IN-176-T	Classrm 176 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-043	FWH-01-CR-IN-175-T	Classrm 175 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422328-044	FWH-01-CR-IN-178-T	Classrm 178 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-045	FWH-01-CR-IN-177-T	Classrm 177 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-046	FWH-01-CR-IN-180-T	Classrm 180 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-047	FWH-01-CR-IN-179-T	Classrm 179 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-048	FWH-02-T-IN-227-T	Library Restrm 227 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-049	FWH-02-T-IN-227B-T	Library 227B Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-050	FWH-02-HA-BY-223-	Bottle Filler By 223					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-051	FWH-02-FR-IN-223-T	Faculty Rm 223 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-052	FWH-02-CR-IN-213-T	Classrm 213 Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.72	5.00	µg/L	06/07/21	JL
422328-053	FWH-02-CR-IN-211-T	Classrm 211 Sink 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-054	FWH-02-CR-IN-211-T	Classrm 311 Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422328-055	FWH-02-CR-IN-208-T	Classrm 208 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-056	FWH-02-CR-IN-209-T	Classrm 209 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-057	FWH-02-CR-IN-206-T	Classrm 206 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-058	FWH-02-CR-IN-207-T	Classrm 207 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-059	FWH-02-CR-IN-204-T	Classrm 204 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-060	FWH-02-CR-IN-205-T	Classrm 205 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-061	FWH-02-CR-IN-202-T	Classrm 202 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-062	FWH-02-CR-IN-203-T	Classrm 203 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-063	FWH-02-CR-IN-200-T	Classrm 200 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-064	FWH-02-CR-IN-201-T	Classrm 201 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-065	FWH-02-T-IN-244-T	Classrm 244 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422328-066	FWH-02-T-IN-246-T	Classrm 246 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-067	FWH-02-CR-IN-271-T	Classrm 271 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-068	FWH-02-T-IN-270-T	Classrm 270 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-069	FWH-02-CR-IN-273-T	Classrm 273 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-070	FWH-02-CR-IN-274-T	Classrm 274 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-071	FWH-02-CR-IN-275-T	Classrm 275 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-072	FWH-02-CR-IN-276-T	Classrm 276 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-073	FWH-02-CR-IN-277-T	Classrm 277 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.11	5.00	µg/L	06/07/21	JL
422328-074	FWH-02-CR-IN-278-T	Classrm 278 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-075	FWH-02-CR-IN-279-T	Classrm 279 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-076	FWH-02-CR-IN-280-T	Classrm 280 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422328-06/09/21 04:28 PM							

Reviewed By:

Analyst

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State	Certificate Number		
New York	ELAP 63556		
Virginia	VELAP 11259		

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422290

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Oliver Middle School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422290-001	01-CO-IN-030A-T	Custodian's Office 030A					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422290-002	01-CR-IN-033-T	Classroom 033 Utility					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 5.98 5.00 µg/L 06/04/21 JL							
422290-003	01-CR-IN-035-T	Classroom 035 Utility					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422290-004	01-CR-IN-037-T	Classroom 037 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
Sample not received.							
422290-005	01-CR-IN-047-T7	Classroom 047 Sink 7					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 7.14 5.00 µg/L 06/04/21 JL							
422290-006	01-CR-IN-047-T6	Classroom 047 Sink 6					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 7.04 5.00 µg/L 06/04/21 JL							
422290-007	01-CR-IN-047-T1	Classroom 047 Sink 1					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 6.96 5.00 µg/L 06/04/21 JL							
422290-008	01-CR-IN-047-T5	Classroom 047 Sink 5					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
Sample not received.							
422290-009	01-CR-IN-047-T2	Classroom 047 Sink 2					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422290-010	01-CR-IN-047-T4	Classroom 047 Sink 4					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
Sample not received.							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.

**Schneider Laboratories Global, Inc**2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422290

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:
Project: Brockport CSD LIW Testing
Location: Oliver Middle School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422290-011	01-CR-IN-047-T3	Classroom 047 Sink 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-012	01-CR-IN-048-T	Classroom 048 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-013	01-HA-BY-044-BF	Bottle Filler By Restroom					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-014	01-KIT-IN-069-T1	Kitchen 069 Prep Sink 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-015	01-KIT-IN-069-PF1	Kitchen 069 Pot Filler 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-016	01-KIT-IN-069-PF2	Kitchen 069 Pot Filler 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-017	01-KIT-IN-069-PF3	Kitchen 069 Pot Filler 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-018	01-KIT-IN-069-T2	Kitchen 069 Prep Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-019	01-KIT-IN-069-T3	Kitchen 069 Prep Sink 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-020	01-KIT-IN-069-IM	Kitchen 069 Ice Machine					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-021	01-FSO-IN-062-T	FSO 062 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.

**Schneider Laboratories Global, Inc**2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422290

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Oliver Middle School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422290-022	01-GO-IN-082-T	Gym Office 082 Restroom					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
9.64	5.00	µg/L	06/04/21	JL			
422290-023	01-CON-IN-084-T	Concession 084 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
<5.00	5.00	µg/L	06/04/21	JL			
422290-024	01-HA-BY-089-BF	BF By Weight Room 089					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
<5.00	5.00	µg/L	06/04/21	JL			
422290-025	01-CUS-IN-099-MS	Custodial Room 099 Mop					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
Sample not received.							
422290-026	01-CUS-IN-099-IM	Custodial Room 099 Ice					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
<5.00	5.00	µg/L	06/04/21	JL			
422290-027	01-CR-IN-007-T	Classroom 007 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
Sample not received.							
422290-028	02-MUS-IN-128-T	Band Room 128 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
<5.00	5.00	µg/L	06/04/21	JL			
422290-029	03-MT-IN-116-T	Auditorium 116 Men's					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
<5.00	5.00	µg/L	06/04/21	JL			
422290-030	03-WT-IN-116-T	Auditorium 116 Women's					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
<5.00	5.00	µg/L	06/04/21	JL			
422290-031	02-HA-BA-160-BF	BF By Room 160					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
<5.00	5.00	µg/L	06/04/21	JL			

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422290

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Oliver Middle School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422290-032	02-CR-IN-153-T1	Classroom 153 Left Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422290-033	02-CR-IN-153-T2	Classroom 153 Right Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 28.5 5.00 µg/L 06/04/21 JL							
422290-034	02-FAC-IN-150-T	Faculty Room 150 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422290-035	02-FAC-IN-150-CT	Faculty Room 150 Coffee					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <10.0 10.0 µg/L 06/08/21 JL							
422290-036	03-HA-BY-127-BF	BF By Restroom 127					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422290-037	03-NO-IN-112-T	Nurse's Office 112 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422290-038	03-T-IN-112-T	Nurse's Office 112					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422290-039	03-GO-IN-101C-T	Gym Office 101C Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 18.1 5.00 µg/L 06/04/21 JL							
422290-040	03-GO-IN-101A-T	Gym Office 101A Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 41.5 10.0 µg/L 06/05/21 JL							
422290-041	04-HA-BY-260-BF	BF By Faculty Room 260					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							
422290-042	05-HA-BY-227-BF	BF By Restroom 227					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/04/21 JL							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #:	422290
-----------------	--------

Matrix	Drinking Water
Received	06/02/21
Reported	06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Oliver Middle School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID Method	Location Result	RL*	Units	Analysis Date	Analyst
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	7.70	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL

422290-06/09/21 04:47 PM

Reviewed By:

Analyst

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State		Certificate Number	
New York		ELAP 63556	
Virginia		VELAP 11259	

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422326

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Brockport High School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422326-001	00-T-IN-044-T	Restroom 044 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	12.6	5.00	µg/L	06/05/21	HI
422326-002	00-T-IN-046-T	Restroom 046 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	14.4	5.00	µg/L	06/05/21	HI
422326-003	00-T-IN-047-T	Restroom 047 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	14.5	5.00	µg/L	06/05/21	HI
422326-004	00-OFF-IN-022-T	Office 022 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-005	00-FIT-IN-020-BF	BF In Weight Room					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-006	00-FIT-IN-020A-MS	Mop Sink In Weight Room					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-007	00-FIT-IN-020A-IM	Ice Machine in Weight					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-008	00-CR-IN-019-T	Classroom 019 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.83	5.00	µg/L	06/05/21	HI
422326-009	00-BT-IN-018B-T2	Boy's Restroom 018B Right					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-010	00-GT-IN-018G-T1	Girl's Restroom 018G Left					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-011	00-BT-IN-018B-T1	Boy's Restroom 018B Left					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422326

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Brockport High School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422326-012	00-GT-IN-018G-T2	Girl's Restroom 018G					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-013	00-HA-BY-014-BF	BF By 014					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-014	00-CR-IN-013-T	Classroom 013 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	23.2	5.00	µg/L	06/05/21	HI
422326-015	00-CR-IN-011-T	Classroom 011 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	16.3	5.00	µg/L	06/05/21	HI
422326-016	00-CR-IN-014-T	Classroom 014 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	101	50.0	µg/L	06/05/21	HI
422326-017	00-BR-IN-002-T	Classroom 014 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	11.1	5.00	µg/L	06/05/21	HI
422326-018	00-BR-IN-002-CT	Break Room 002 Coffee					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-019	01-BT-IN-138B-T1	Boy's Restroom 138B Left					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-020	01-BT-IN-138B-T2	Boy's Restroom 138B Right					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-021	01-BT-IN-138G-T	Girl's Restroom 138G					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	50.4	10.0	µg/L	06/05/21	HI
422326-022	01-LR-IN-194-T	Laundry Room 194 Tap					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422326

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:
Project: Brockport CSD LIW Testing
Location: Brockport High School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422326-023	01-BLR-IN-135B-T	Boy's Locker Room 135B					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-024	01-T-IN-137-T	Offical's Restroom 137					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 17.4 5.00 µg/L 06/05/21 HI							
422326-025	01-GLR-IN-135G-T	Girl's Locker Room 135G					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-026	01-HA-BY-134-BF	BF By 134					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-027	01-BLR-IN-132-T	Boy's Locker Room 132 Tap					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 7.74 5.00 µg/L 06/05/21 HI							
422326-028	01-T-IN-196A-T	Coach's Office Restroom					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 7.30 5.00 µg/L 06/05/21 HI							
422326-029	01-T-IN-196B-T	Coach's Office Restroom					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 6.39 5.00 µg/L 06/05/21 HI							
422326-030	01-GYM-IN-196E-BF	Eastern BF In Gym 196					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-031	01-CR-IN-193-T	Classroom 193 Tap Utility					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 82.4 20.0 µg/L 06/08/21 JL							
422326-032	01-CR-IN-192-T	Classroom 192 Tap Utility					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-033	01-CR-IN-190-T	Classroom 190 Tap Utility					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.

**Schneider Laboratories Global, Inc**2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422326

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Brockport High School
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
422326-034	01-CR-IN-189-T	Classroom 189 Tap Utility					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-035	01-STG-IN-180-T	Stage Changing 180 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 20.1 5.00 µg/L 06/05/21 HI							
422326-036	01-T-IN-181Q-T	Music Wing Restroom Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-037	01-STOR-IN-181F-T	Music Wing Storage Room					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-038	01-BLR-IN-195-T	Boy's Locker Room 195					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 7.51 5.00 µg/L 06/05/21 HI							
422326-039	01-GLR-IN-197-T1	Girl's Locker Room 197					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 55.3 10.0 µg/L 06/05/21 HI							
422326-040	01-RM-IN-199-MS	Mop Sink In Room 199					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-041	01-T-IN-196E-T	Coach's Office Restroom					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-042	01-GYM-IN-196W-BF	Western BF In Gym 196					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-043	01-CR-IN-198-T	Classroom 198 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 8.02 5.00 µg/L 06/05/21 HI							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.

**Schneider Laboratories Global, Inc**2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422326

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Brockport High School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422326-044	01-NO-IN-175D-T	Nurse's Exam Room D Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2							
Sample not received.							
422326-045	01-NO-IN-175C-T	Nurse's Exam Room C Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 21.4 5.00 µg/L 06/05/21 HI							
422326-046	01-NO-IN-175B-T	Nurse's Exam Room B Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-047	01-NO-IN-175A-T	Nurse's Exam Room A Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-048	01-CO-IN-176-T	Custodian's Office 176					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-049	01-HA-BY-167-BF	BF By 167					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-050	01-CR-IN-167-T	Classroom 167 Tap					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-051	01-MT-IN-166A-T	Men's Toilet 166A Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-052	01-WT-IN-166B-T	Women's Toilet 166B Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-053	01-KIT-IN-166-T	Kitchenette 166 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422326

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Brockport High School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422326-054	01-KIT-IN-166-CT	Kitchenette 166 Coffee					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-055	01-T-IN-165D-T	Restroom 165D Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-056	01-T-IN-165C-T	Restroom 165C Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-057	01-T-IN-165B-T	Restroom 165B Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-058	01-T-IN-165A-T	Restroom 165A Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-059	01-BR-IN-139-T	Break Room 139 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-060	01-BR-IN-139-CT	Break Room 139 Coffee					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-061	01-KIT-IN-140-T5	Kitchen 140 Sink 5 Hand					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-062	01-KIT-IN-140-T1	Kitchen 140 Sink 1 Hand					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-063	01-KIT-IN-140-T2	Kitchen 140 Sink 2 Prep 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
422326-064	01-KIT-IN-140-SP	Kitchen 140 Sprayer					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422326

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Brockport High School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422326-065	01-KIT-IN-140-PF1	Kitchen 140 Pot Filler 1					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-066	01-KIT-IN-140-PF2	Kitchen 140 Pot Filler 2					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-067	01-KIT-IN-140-PF3	Kitchen 140 Pot Filler 3					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 12.4 5.00 µg/L 06/05/21 HI							
422326-068	01-KIT-IN-140-T3	Kitchen 140 Sink 3 Prep 2					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-069	01-KIT-IN-140-T4	Kitchen 140 Sink 4 Hand					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-070	01-KIT-IN-140-IM	Kitchen 140 Ice Machine					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-071	01-BR-IN-114-CT	Brteak Room 114 Coffee					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-072	01-HA-BY-113-BF	BF By 113					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-073	01-BT-IN-112B-T2	Boy's Restroom 112B Right					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-074	01-GT-IN-112G-T1	Girl's Restroom 112G Left					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-075	01-BT-IN-112B-T1	Boy's Restroom 112B Left					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422326

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Brockport High School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422326-076	01-GT-IN-112G-T2	Girl's Restroom 112G					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-077	01-MT-IN-109-T	Men's Toilet 109 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-078	01-WT-IN-107-T	Women's Toilet 107 Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-079	02-BT-IN-212B-T2	Boy's Restroom 212B Right					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-080	02-GT-IN-212G-T1	Girl's Restroom 212G Left					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-081	02-BT-IN-212B-T1	Boy's Restroom 212B Left					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-082	02-GT-IN-212G-T2	Girl's Restroom 212G					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-083	02-HA-BY-211-BF	BF By 211					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-084	02-T-IN-265D-T	Restroom 265D Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-085	02-T-IN-265C-T	Restroom 265C Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							
422326-086	02-T-IN-265B-T	Restroom 265B Sink					
Metals Analysis							
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/05/21 HI							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422326

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD LIW Testing
Location: Brockport High School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/05/21	HI

422326-06/09/21 04:40 PM

Reviewed By:

Analyst

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State	Certificate Number		
New York	ELAP 63556		
Virginia	VELAP 11259		

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422284

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:

Project: Brockport CSD Lead In Water
Location: Bus Garage
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID Method	Location Result	RL*	Units	Analysis Date	Analyst
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL

422284-06/09/21 04:57 PM

Reviewed By:

Analyst

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #:	422286
-----------------	--------

Matrix	Drinking Water
Received	06/02/21
Reported	06/09/21


Attn:

Project: Brockport CSD Lead In Water
Location: Administration Building
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID Method	Location Result	RL*	Units	Analysis Date	Analyst
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<10.0	10.0	µg/L	06/08/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	16.6	5.00	µg/L	06/04/21	JL

422286-06/09/21 04:55 PM


 Reviewed By: _____
 Analyst
EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State		Certificate Number	
New York		ELAP 63556	
Virginia		VELAP 11259	

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #:	422285
-----------------	--------

Matrix	Drinking Water
Received	06/02/21
Reported	06/09/21

Attn:

Project: Brockport CSD Lead In Water
Location: TTC Building
Number: 2211782

PO Number:

Sample ID Parameter	Cust. Sample ID Method	Location Result	RL*	Units	Analysis Date	Analyst
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<10.0	10.0	µg/L	06/08/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
Metals Analysis						
Lead	EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL

422285-06/09/21 04:59 PM

Reviewed By:

Analyst

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State			Certificate Number
New York			ELAP 63556
Virginia			VELAP 11259

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 424567

Matrix Drinking Water
Received 06/15/21
Reported 09/15/21

Attn:

Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Method	Result	RL*	Units	Analysis Date	Analyst
Parameter								
424567-001	BHS-00-CR-IN-013-T	Classroom 013 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 30.4 5.00 µg/L 06/26/21 HI								
424567-002	BHS-00-CR-IN-011-T	Classroom 011 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 9.67 5.00 µg/L 06/26/21 HI								
424567-003	BHS-00-CR-IN-014-T	Classroom 014 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 29.9 5.00 µg/L 06/26/21 HI								
424567-004	BHS-01-BT-IN-138G-	Girl's Restroom 138G Tap						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 55.1 25.0 µg/L 06/26/21 HI								
424567-005	BHS-01-T-IN-137-T	Official's Restroom 137						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 11.2 5.00 µg/L 06/26/21 HI								
424567-006	BHS-01-STG--IN-180	Stage Chnging Rm 180 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 11.4 5.00 µg/L 06/26/21 HI								
424567-007	BHS-01-GLR-IN-197-	Girl's Lcker Room 197 L						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 25.4 5.00 µg/L 06/26/21 HI								
424567-008	BHS-01-GLR-IN-197-	Girl's Lcker Room 197 R						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 37.2 5.00 µg/L 06/26/21 HI								
424567-009	BHS-01-NO-IN-175D-	Nurse's Exam Room D Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 22.8 5.00 µg/L 06/26/21 HI								
424567-010	BHS-01-NO-IN-175C-	Nurse's Exam Room C Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 54.4 25.0 µg/L 06/26/21 HI								
424567-011	GIN-01-T-IN-505-T	Restroom 505 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 27.6 5.00 µg/L 06/26/21 HI								

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 424567

Matrix Drinking Water
Received 06/15/21
Reported 09/15/21

Attn:

Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Method	Result	RL*	Units	Analysis Date	Analyst
Parameter								
424567-012	GIN-01-LIB-IN-316A-	Library 316A Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-013	GIN-01-CR-IN-321-T	Classroom 321 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 5.32 5.00 µg/L 06/26/21 HI								
424567-014	GIN-01-CR-IN-314-T	Classroom 314 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-015	GIN-01-CR-IN-308-T	Classroom 308 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 13.3 5.00 µg/L 06/26/21 HI								
424567-016	OMS-01-CR-IN-037-T	Classroom 037 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 6.28 5.00 µg/L 06/26/21 HI								
424567-017	OMS-01-CR-IN-047-T	Classroom 047 Sink 5						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-018	OMS-01-CR-IN-047-T	Classroom 047 Sink 3						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 6.46 5.00 µg/L 06/26/21 HI								
424567-019	OMS-01-CUS-IN-099-	Custodial Room 099 Mop						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 6.06 5.00 µg/L 06/26/21 HI								
424567-020	OMS-01-CR-IN-007-T	Classroom 007 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-021	OMS-01-CR-IN-153-T	Classroom 153 R Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 36.5 5.00 µg/L 06/26/21 HI								
424567-022	OMS-03-GO-IN-101C	Gym Office 101C Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 21.7 5.00 µg/L 06/26/21 HI								

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 424567

Matrix Drinking Water
Received 06/15/21
Reported 09/15/21

Attn:

Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Method	Result	RL*	Units	Analysis Date	Analyst
Parameter								
424567-023	OMS-03-GO-IN-101A	Gym Office 101A Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 41.7 10.0 µg/L 06/26/21 HI								
424567-024	FWH-01-KIT-IN-119-	Kitchen 119 Pot Filler 1						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 17.8 5.00 µg/L 06/26/21 HI								
424567-025	FWH-01-RM-IN-130-	Room 130 Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-026	FWH-01-HA-BY-162-	BF By Restroom 162						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-027	FWH-01-T-IN-162-T2	Restroom 162 R Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-028	TTC-01-GT-IN-25-T1	Girl's Restroom Sink 1						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-029	TTC-01-GT-IN-25-T2	Girl's Restroom Sink 2						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-030	TTC-01-GT-IN-25-T3	Girl's Restroom Sink 3						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-031	TTC-01-BT-IN-27-T3	Boy's Restroom Sink 3						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-032	TTC-01-BT-IN-27-T2	Boy's Restroom Sink 2						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-033	TTC-01-BT-IN-27-T1	Boy's Restroom Sink 1						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 424567

Matrix Drinking Water
Received 06/15/21
Reported 09/15/21

Attn:

Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Method	Result	RL*	Units	Analysis Date	Analyst
Parameter								
424567-034	CON-01-KIT-IN-CON-	Conc Mop Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-035	CON-01-KIT-IN-CON-	Conc Kitchen Sink 1						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-036	CON-01-KIT-IN-CON-	Conc Kitchen Sink 2						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-037	CON-01-KIT-IN-CON-	Conc Kitchen Sink 3						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-038	CON-01-EXT-BY-CO	Hose Bib By Bathrooms						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 19.7 5.00 µg/L 06/26/21 HI								
424567-039	CON-01-EXT-BY-CO	Hose Bib By Serving						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 59.9 10.0 µg/L 06/26/21 HI								
424567-040	CON-01-EXT-BY-CO	Field Hose Line East Side						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 24.2 5.00 µg/L 06/26/21 HI								
424567-041	CON-01-EXT-BY-CO	Field Hose Line West Side						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 62.5 25.0 µg/L 06/26/21 HI								
424567-042	OPS-01-KIT-IN-OPS-	Operations Kitchen Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-043	OPS-01-HA-IN-OPS-	Operations BF						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								
424567-044	OPS-01-SHP-IN-OPS	Operations Shop Sink						
Metals Analysis								
Lead EPA 200.9 Rev 2.2 <5.00 5.00 µg/L 06/26/21 HI								

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 424567

Matrix Drinking Water
Received 06/15/21
Reported 09/15/21

Attn:

Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Method	Result	RL*	Units	Analysis Date	Analyst
Parameter								
424567-045	OPS-01-KIT-IN-OPS-	Operations Kitchen Coffee						
Metals Analysis								
Lead								
	EPA 200.9 Rev 2.2		<5.00	5.00	µg/L		06/29/21	SA
424567-046	MNT-01-KIT-IN-MNT-	Grounds Kitchen Sink						
Metals Analysis								
Lead								
	EPA 200.9 Rev 2.2		<5.00	5.00	µg/L		06/26/21	HI
424567-047	MNT-01-HA-IN-MNT-	Grounds Drinking Fountain						
Metals Analysis								
Lead								
	EPA 200.9 Rev 2.2		<5.00	5.00	µg/L		06/26/21	HI
424567-048	MNT-01-KIT-IN-MNT-	Grounds Kitchen Coffee						
Metals Analysis								
Lead								
	EPA 200.9 Rev 2.2		<5.00	5.00	µg/L		06/29/21	SA
424567-049	BAR-01-T-IN-101C-T	Restroom 101C Sink						
Metals Analysis								
Lead								
	EPA 200.9 Rev 2.2		14.8	5.00	µg/L		06/26/21	HI
424567-050	BAR-01-KIT-IN-106-T	Kitchen 106 Sink 1						
Metals Analysis								
Lead								
	EPA 200.9 Rev 2.2		<5.00	5.00	µg/L		06/26/21	HI
424567-051	BAR-01-EXT-BY-606-	Ext by Classroom 606 Hose						
Metals Analysis								
Lead								
	EPA 200.9 Rev 2.2		36.5	5.00	µg/L		06/26/21	HI
424567-052	BAR-01-CR-IN-120-T	Office 120 Sink						
Metals Analysis								
Lead								
	EPA 200.9 Rev 2.2		31.9	5.00	µg/L		06/26/21	HI
424567-053	BAR-01-T-IN-120-T	Office Restroom 120 Sink						
Metals Analysis								
Lead								
	EPA 200.9 Rev 2.2		54.6	10.0	µg/L		06/26/21	HI

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.

**Schneider Laboratories Global, Inc**2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 424567

Matrix Drinking Water
Received 06/15/21
Reported 09/15/21

Attn:

Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Parameter	Method	Result	RL*	Units	Analysis Date	Analyst
424567-09/15/21 02:23 PM									

Reviewed By:

Approved Signatory

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State	Certificate Number		
New York	ELAP 63556		
Virginia	VELAP 11259		

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.

Appendix C

Laboratory Certification



ANDREW M. CUOMO
Governor

Department of Health

HOWARD A. ZUCKER, M.D., J.D.
Commissioner

LISA J. PINO, M.A., J.D.
Executive Deputy Commissioner

March 31, 2021

ELAP ID 11413
SCHNEIDER LABORATORIES GLOBAL, INC
MR. FAYEZ ABOUZAKI
2512 WEST CARY STREET
RICHMOND, VA 23220-5117
ifaszewski@slabinc.com

Certified Mail & Email

Dear Mr. Abouzaki,

The review of your laboratory's renewal application through the New York State (NYS) Department of Health's Environmental Laboratory Approval Program (ELAP) for a certificate of approval will require the evaluation of additional information, and therefore has not been completed. Please note that Article 4, Section 401, and Subsection 2 of the State Administrative Procedure Act states:

"When a licensee has made timely and sufficient application for a renewal of a license or a new license with the reference to any activity of a continuing nature, the existing license does not expire until the application has been finally determined by the agency ..."

The 2020-2021 NYS ELAP certificate of approval issued to your laboratory remains in effect, without regard to the expiration date of April 1, 2021, printed on the certificate. A copy of this letter may be provided to any person inquiring as to the status of your certificate.

If you have any questions, please contact ELAP at the New York State Department of Health, Wadsworth Center, Empire State Plaza, Albany, NY 12237; by phone at (518) 485-5570; or by email at elap@health.ny.gov.

Sincerely,

A handwritten signature in cursive ink that reads "Victoria Pretti".

Victoria A. Pretti
Director and QA Officer

cc. L. McNaughton

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2021
Issued April 01, 2020

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER*

All approved analytes are listed below:

Metals I

Lead, Total

EPA 200.9 Rev. 2.2



**Department
of Health**

Serial No.: 61370

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

